



宁波正欣消防设备有限公司
NingBo ZhengXin Fire-Fighting Equipment Co., Ltd.

Declaration Of Conformity



Issued in accordance with the Pressure Equipment
Directive 2014/68/EU

We hereby declare that the product(s) listed below have been manufactured in accordance with the above-mentioned Directive for use with non-hazardous fluids of Groups 2.

Product Description: Mobile Fire Extinguisher Steel & Stainless Steel (Assembly)

Order No.	Type	Quantity	Serial (Batch) Number
ZX-EX-210911	9L	800	000013-000812/ 000813

Maximum Allowable Pressure PS: 20 bar
Test Pressure PT: 30 bar
Temperature Range : See Technical Files
Applicable Standards & Directives: EN1866 & 2014/68/EU
Conformity assessment modules(s) used: B+D
B Certificate Reference Number: 13/CN/3248
D Certificate Reference Number: 12/CN/2860

The Technical Documentation has been approved by

The products have been inspected by

Notify Body: **APRAGAZ**

Vilvoordsesteenweg 156,

B-1120 Brussel, Belgium

Identification Number: **0029**

Date: 2021-10-19

Signature:

On Behalf of NingBo ZhengXin Fire Fighting Equipment Co.Ltd.

宁波正欣消防设备有限公司
NINGBO ZHENGXIN FIRE-FIGHTING EQUIPMENT CO., LTD.

Address: HuangJiaBu Town, YuYao City, 315466, ZheJiang, CHINA.

Factory TEL : +86 574 6200 3658

FAX: +86 574 6200 3688

E-mail: info@zxfire.net

Website: Http://www.zxfire.net